

# ENERGYGUIDE


Central Air Conditioner  
Cooling Only  
Split System

XYZ Corporation  
Model HC47  
Capacity 57,000 Btu/h



## Efficiency Rating (SEER)\*

13.0-14.2




Range of Similar Models  
\* Seasonal Energy Efficiency Ratio

▼▼ This system's efficiency rating depends on the coil your contractor installs with this unit. Ask for details.

For energy cost info, visit [productinfo.energy.gov](http://productinfo.energy.gov)

## Notice

The installed system must meet minimum federal regional efficiency standards. See [productinfo.energy.gov](http://productinfo.energy.gov) for certified coil combinations.



- North**    □ AK, CO, CT, ID, IL, IA, IN, KS, MA, ME, MI, MN, MO, MT, ND, NE, NH, NJ, NY, OH, OR, PA, RI, SD, UT, VT, WA, WV, WI, WY
- Southeast**    ■ AL, AR, DC, DE, FL, GA, HI, KY, LA, MD, MS, NC, OK, SC, TN, TX, VA, U.S. Territories
- Southwest**    ■ AZ, CA, NM, NV

### Minimum Standards

	North	Southeast	Southwest
SEER	13	14	14
EER <sup>†</sup>			12.2
EER <sup>††</sup>			11.7

<sup>†</sup> Units with rated capacity of less than 45,000 btu/h  
<sup>††</sup> Units with rated capacity equal to or greater than 45,000 btu/h

**Energy Efficiency Ratio (EER):** could range from 11.4 to 12.5, depending on the coil installed with this unit